


"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"



**DELHI JAL BOARD ;(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT HAIDERPUR,
DELHI-110085**



(ISO Certified 9001:2015)

THE TEST REPORT IS
FOR THE
WATER

Water sample collected from drinking point after R/O system in the premises of Vanasthali Public School, Ghevra road, Nizampur Delhi-110081 vide challan No. 04 Dated 03.04.2023.

S. No.	PARAMETERS	UNITS	Limit as per B.I.S.10500:2012		S1
			Acceptable	Permissible	
1.	Date of collection	--	---	---	12.04.2023
2.	Date of Analysis	--	---	---	14.04.2023
3.	Colour	C.U.	5	15	<1 C.U.
4.	Odour	--	Agreeable		Agreeable
5.	Turbidity	N.T.U	1.0	5.0	1.28
6.	p ^H value	--	6.5 to 8.5	N.R.	6.8
7.	Electrical Conductivity	µmhos/cm	---	---	149.26
8.	Total Dissolved Solid	(mg/l)	500	2000	97.02
CHEMICAL EXAMINATION					
9.	Phenolphthalein Alkalinity	(mg/l)	---	---	Nil
10.	Total Alkalinity	(mg/l)	200	600	24.0
11.	Total Hardness	(mg/l)	200	600	28.0
12.	Calcium Hardness	(mg/l)	200	600	16.0
13.	Magnesium Hardness	(mg/l)	200	600	12.0
14.	Calcium as Ca	(mg/l)	75	200	6.4
15.	Magnesium as mg	(mg/l)	30	100	2.88
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	*ND
17.	Nitrite -Nitrogen (N)	(mg/l)	---	---	*ND
18.	Nitrate (NO ₃)	(mg/l)	45	N.R.	1.07
19.	Sulphate (SO ₄)	(mg/l)	200	400	0.11
20.	Chloride (Cl)	(mg/l)	250	1000	22.0
21.	Iron (Fe)	(mg/l)	1.0	N.R.	0.02
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.18
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	*N.D.
24.	Residual Chlorine	(mg/l)	0.2	1.0	Nil
BACTERIOLOGICAL EXAMINATION					
25.	Coli form per 100 ml at 37°C	MPN/100 mL	0		0

*N.D. - Not Detectable

Remarks: On the basis of above tested parameters, water sample (S1) confirm to drinking water specification I.S.10500:2012 and may be used for drinking purpose.

Asstt. Chemist

Chemist/Bacteriologist

A.C.W.A. (HP- I)

C.W.A. (W&S)-II

Manager

PRINCIPAL
VANASTHALI PUBLIC SCHOOL
NIZAMPUR GHEVRA ROAD
NIZAMPUR, DELHI-110081